



PETROCHEMICAL INDUSTRIES
DESIGN & ENGINEERING CO.

PROJ. NO. : 1205



DENA METHANOL PLANT

شرکت صنایع پتروشیمی دنا
Dena Petrochemical Industries Co.

COVER SHEET

OWNER :

SABALAN PETROCHEMICAL INDUSTRIES CO.

PROJ. NO. : 89/S-G/102

DATA SHEET

For

ROOF TYPE EXHAUST FAN FOR DIESEL GENERATOR ROOM IN SUBSTATION

DOCUMENT NO. : 1205-00-HV-DSH-027

TOTAL PAGES : 1 (Excluding Cover & Revision Index Sheets and attachments)

Note: For relevant records of the document, reference can be made to Sabalan Methanol Project documentation.

ED		EXT		IFE		A
Eng. Phase		Purpose Of Distribution (POD)		Purpose Of Issue (POI)		Owner's Action
00	15.10.2016	ISSUED FOR ENGINEERING		M.Mashayekh	M.Momenaie	A.Moadeli
Rev.	Date	Description		Prepared by	Checked by	Approved by
						Project

PROJ. NO. : 1205



DENA METHANOL PLANT

Data Sheet for Roof Type Exhaust Fan for Diesel Generator Room in Substation

Doc. No.: 1205-00-HV-DSH-027

Rev. : 00





OWNER :

SABALAN PETROCHEMICAL INDUSTRIES CO.

PROJ. NO. : 89/S-G/102

[illegible]

	PETROCHEMICAL INDUSTRIES DESIGN & ENGINEERING CO. PROJ. NO. : 1205	 DENA METHANOL PLANT Data Sheet for Roof Type Exhaust Fan for Diesel Generator Room in Substation Doc. No.: 1205-00-HV-DSH-027 Rev. : 00	OWNER : SABALAN PETROCHEMICAL INDUSTRIES CO. PROJ. NO. : 89/S-G/102

NO.	GENERAL									
1	Tag No. REX-0037									
2	Duty Permanent									
3	Type ☐ Wall Mounted ☐ Duct Mounted ☐ Utility (Centrifugal) ☒ Roof Type ☐ Other									
4	Quantity (Working + Standby) 1					Operating Weight Kg *				
5	Service Diesel Generator Room					Type of Driver El. Motor				
6	Overall Size l x w x h m x m x m *					Installation Outdoor				
7	Inlet : (Single / Double) Single					Impeller Type *				
8	SITE CONDITION									
9	Location / Latitude					Assaluyeh / 28.5° N				
10	Altitude m					34				
11	Ambient Air Temperature Max / Min °F					118.4 / 41				
12	Wet Bulb Temp °F					91.4				
13	OPERATING CONDITIONS									
14	Gas Composition Air					Suction Press. in.w.g -0.2				
15	Molecular Weight 29					Discharge Pressure in.w.g Atm.				
16	Air Flow Rate Rated cfm 170					Differential Pressure in.w.g 0.2				
17	Normal cfm 155					Suc. Temp. Min °F -				
18	Relative Humidity at Suction Max % 65					Max °F 89.6				
19	FAN DATA					MOTOR DATA				
20	Make/Origin * / *					Make/Origin * / *				
21	Model No. *					Model No. *				
22	Fan Diameter m *					Input Power Kw *				
23	Fan Speed rpm *					Speed rpm *				
24	Material / Thickness Casing mm * / *					Insulation Class / Temperature Rise * / *				
25	Impeller mm * / *					Power Supply V/Ph/Hz 400 / 3 / 50				
26	Material Shaft *					Degree of Protection IP 55				
27	Pulley *					System Full Load Current A *				
28	Material / Make / Origin Belt * / * / *					System Power Factor % *				
29	Finish Casing *					Hazardous Classification Unclassified				
30	Impeller *					Motor Efficiency % *				
31	ACCESSORIES									
32	Required More Specification					Required More Specification				
33	Pulley Guard * *					Base Yes * steel channel profile				
34	Belt Guard * *					Safety Screen Outlet *				
35	Bearing Guard * *					Vibration Isolator Yes *				
36	Air Flow Switch / Model No. Yes *					Gravity Damper Yes *				
37	Drain Hole N.A. *					Inlet Connection Yes Flanged				
38	Elec. Terminal Junction Box Yes IPW 55, With Cable Gland					Outlet Connection No -				
39	LOCAL CONTROL STATION									
40	Required N.A.					Installation Location -				
41	On / Off / Trip Indicating Lights -					Degree of Protection -				
42	Start / Stop Push Buttons -					Hazardous Classification -				
43	Miscellaneous Requirements -									
44	NOISE SPECIFICATION									
45	Noise level @ 1 meter from ex. Fan db *					Noise level @ exhaust air db *				
46	DIRECTION OF DISCHARGE (N.A.)									
47	☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐									
48	       									
49										
50										
51										

REMARKS:

- 1 * To be filled by vendor.
- 2 IPW 55 protection for junction boxes, motor terminal boxes, control stations, panel boards, and auxiliary equipment should be considered.
- 3 N.A. Not Applicable.